STATE OF UTAH DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT

UTAH NATIONAL GUARD WEST JORDAN AASF ROOFING SYSTEM REPLACEMENT

PROJECT NUMBER: 08265480

GENERAL NOTES

- 1. The General Contractor, all suppliers and subcontractors will follow the direction of the Owner to maintain undisturbed all areas of the site that are outside the project limit line.
- 2. The purpose of the contract documents is to describe the design intent of the proposed improvements. In order to fully understand the scope of the work involved the general and sub contractors are responsible for visiting the site and studying the contract documents prior to bidding or commencing work. The General and sub contractors will be responsible for providing all work and materials related to the construction described, whether fully specified or not, such as fasteners, connectors, caulking, hardware, finishes and other such work that would constitute a complete application.
- The contractor and subcontractors shall verify all dimensions and conditions at the site and work performed by other trades. Do not scale drawings. If dimensions are in question the Contractor or subcontractor shall be responsible for obtaining clarification from the architect prior to continuing construction of the area in question.
- 4. Dimensions are to be to the centerline of steel, the nominal face of concrete or masonry and the finish face of studs, unless otherwise noted.
- 5. All details, sections, and notes shown on the drawings are intended to be typical and shall apply to similar situations elsewhere unless noted or shown otherwise. Notes and details on drawings shall take precedence over these general notes. If general notes and specifications appear to be in conflict contact architect for clarification before proceeding with construction.
- 6. During and after construction the contractor and/or owner shall keep the loads on the structure within the limits of the design loads.
- 7. "Typ." or "Typical", as used in these documents, mean that the condition is the same or representative for all similar conditions unless otherwise noted. Details are usually keyed and noted "typical" only when they first occur and are representative for similar conditions throughout, unless noted otherwise.
- 8. Furnish every thing necessary and incidental for proper and satisfactory completion of all work specified, indicated or shown in the contract documents.

9. All exposed surfaces that have been modified, installed or affected by the construction process shall be cleaned, vacuumed or dusted in order to leave the premises ready for occupancy

REINF

REV.

R.O.

S.C.

SD. SHT.

SIM.

SPEC

STD.

STL.

SYST.

T & B

T & G

T.O.

T.O.F.

T.O.W.

TYP.

T.S.

WD.

W.W.F

STRUCT.

SCHED.

Reinforced concrete

Revised, Revision, Reversed

masonry unit

Roof drain

Reinforcing Required

Sewer line

Solid core

Schedule

Schedule

Specification

Top and bottom

Top of footing

Steel tube column

Unless noted otherwise

Top of wall

Tongue and groove

Standard

Structural

System

Top of

Typical

Vertical

Water

Wood

Waterproof

Water resistant

Welded wire fabric

Welded wire mesh

With

Sheet

Steel

Similar

Rough opening

Regular Rough-sawn

Radius

Room

10. Patch and repair all finished surfaces damaged by construction to the satisfaction of the owner.



Index of Drawings

Abbreviations

F.D.

F.E.

FDN.

Air conditioning

ACOUST. ADJ. ALLOW. ALUM.	Air conditioning Acoustical Adjustable Allowance Aluminum	F.R. F.S.R. FTG.	Floor Fire rated Flexible sheet roofing Footing
ANOD. APPROP. APPROX.	Anodized Appropriate Approximate	G G.I. GA. GAL.	Gas Galvanized iron Gauge Galvanized
B.U.R. BLDG. BLK. BRK.	Built up roof Building Block Brick	GRD. GYP. BD. G.L.B.	Grade Gypsum board Glued laminated beam
C.I. C.J. C.M.U.	Cast iron Control joint Concrete masonry unit	H.B. HD. H.M. HORIZ.	Hose bib Head Hollow metal Horizontal
CLG. COL. COOR. CONC. CONST. CONTR.	Ceiling Column Coordinate Concrete Construction Contractor	I.D. INCL. INT. IRRIG. INSUL.	Inside diameter Included Interior Irrigation Insulation
D.F. DIA. DIM. DN. DWG.	Continuous Drinking fountain Diameter Dimension Down Drawing	M.R. MFR MAX. MECH. MIN. M.D.F.	Moisture resistant Manufacturer Maximum Mechanical Minute Medium Density Fiberboard
DWG. DTL. EA. E.F.	Drawings Detail Each Exhaust fan	N.I.C. N.T.S. NO. #	Not in contract Not to scale Number Number
E.I.F.S. E.J. ELECT. ELEV. EQ.	Exterior insulation finish system Expansion joint Electric, Electrical Elevation Equal	O.C. O.D. OFD. OPN'G OPHD	On center Outside diameter Overflow drain Opening Opposite hand
E.W. EXIST. EXT.	Each way Existing Exterior	P.L. PLYWD.	Plastic Laminate Plywood

PNT.


PNTD.

PROJ.

PTD.

PR.

Symbols



Code Information

2006 INTERNATIONAL BUILDING CODE EXISTING ROOF AREA A = 24,600 S.F. EXISTING ROOF AREA B = 8,300 S.F.OCCUPANCY GROUP = B & E

CONSTRUCTION TYPE = V-A (MASONRY INTERIOR AND EXTERIOR WALLS WITH STEEL OPEN WEB JOISTS)

MINIMUM ROOF COVERING CLASSIFICATION REQUIRE = CLASS B ROOF CLASSIFICATION PROVIDED = CLASS B

<u>mae</u> ,	x of Drawings
G101	TILE SHEET
D101	DEMOLITION ROOF PLAN - AREA A
D102	DEMOLITION ROOF PLAN - AREA B
A102	ROOF PLAN - AREA A
A102	ROOF PLAN - AREA B
A201	ROOF DETAILS
A202	ROOF DETAILS
A203	ROOF DETAILS
A204	ROOF DETAILS

Directory

OWNER:

STATE OF UTAH DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT

PROJECT MANAGER

LUCAS V. DAVIS STATE OFFICE BLDG. ROOM 4110 Salt Lake City, Utah 84114 PHONE: (801) 538-3791 FAX: (801) 538-3267

ARCHITECT:

Tracy Stocking & Associates Malcolm Campbell, AIA — Project Architect 17 Exchange Place Salt Lake City, Utah 84111 (801) 463-7108

UTAH UCTION AND M AL GUARD NATIONAL OF STATE WES ROOFING S PROJE Description: TITLE SHEET TSA Project

C COPYRIGHT 2005 TRACY STOCKING & ASSOCIATES ALL RIGHTS RESERVED

Number: 0826 GIC 09/08/2008

Floor drain

Foundation

Finish

Fire extinguisher


Paint


Pair


Painted

Painted

Project







GENERAL NOTES

- 1. INSTALL NEW ROOF SYSTEM OVER LOW SLOPE ROOF AREAS UNLESS INDICATED OTHERWISE
- 2. INSTALL COATED METAL DRIP EDGES AND WELD TO MEMBRANE AT ROOF
- PROVIDE TAPERED INSULATION CRICKETS BETWEEN PRIMARY ROOF DRAINS IN ADDITION TO BASE INSULATION.
- INSTALL NEW DRAIN INSERT IN EXISTING DRAIN BOWLS. SEE DETAILS.
- EFFORT HAS BEEN MADE TO IDENTIFY ALL PIPE AND FLUE PENETRATIONS ON THESE ROOF PLANS, CONTRACTOR IS RESPONSIBLE TO VERIFY ALL PIPE AND FLUE PENETRATIONS IN FIELD AND PROVIDE NEW FLASHING AS SHOWN ON
- BID ROOF AREA B AS ALTERNATE 1
 - TAPERED INSULATION CRICKETS INDICATED ON ROOF PLAN ARE GENERIC. THE CONTRACTOR MAY PROVIDE AN ALTERNATE DESIGN SUBJECT TO THE SLOPE MEETING THE REQUIREMENTS OF THE MEMBRANE MANUFACTURER'S WARRANTEE AND THE INTERNATIONAL BUILDING CODE.
- ANTENNA TOWERS AND GUY-LINES TO BE REMOVED AND REINSTALLED BY CONTRACTOR. ANTENNA WIRING TO BE RECONNECTED BY OWNER.
- LOCATION OF ANTENNA BASES AND ANCHORS IS FLEXIBLE AND MAY REQUIRE MODIFICATION FOR BELOW DECK ACCESS. INTERIOR CEILINGS ARE LAY-IN ACOUSTIC TILE. ANCHORS MUST BE INSTALLED AT A MINIMUM THE DISTANCE FROM THE MAST INDICATED ON THE ROOF PLAN.
- HAVE NEW ANTENNA BASES AND ANCHORS INSTALLED AND READY TO RECEIVE ANTENNAS AND GUY-LINES PRIOR TO DISCONNECTING AND REMOVING THEM.
- NOTIFY BUILDING OCCUPANT ONE WEEK BEFORE REMOVAL OF ANY ANTENNA EQUIPMENT TO COORDINATE SCHEDULE. FOR 50' MAST, COORDINATE DOWN TIME AND RECONNECTION OF ANTENNA WIRING WITH OWNER. FOR ALL OTHER ANTENNAS DOWN TIME IS 8 HOURS AND ANTENNAS MUST REINSTALLED BY 4:00 PM.

NEW ROOF SYSTEM

AND PVC ROOFING MEMBRANE MECHANICALLY ATTACHED.

CLASS-A OR B ROOF COVERING OVER NON COMBUSTIBLE DECK (2) 1½" LAYERS OF POLYISOCYANURATE INSULATION PLACED DIRECTLY OVER DECK

ALL INSULATION JOINTS MUST BE STAGGERED A MINIMUM OF 6 IN. FROM THE DECK JOINTS OR FROM THE INSULATION JOINTS DIRECTLY BELOW.

PROVIDE TAPERED INSULATION CRICKETS BETWEEN DRAINS TO ACHIEVE MINIMUM INCLINE OF $\frac{1}{4}$:12. THE MAXIMUM INCLINE SHALL NOT EXCEED $\frac{1}{2}$:12.

NEW WOOD FOR CURBS TO BE FIRE RESISTIVE TREATED LUMBER

MECHANICAL NOTES

1. ALL HEATING AND VENTILATING EQUIPMENT SHALL BE INSTALLED IN ACCORDANCE WITH CURRENT MECHANICAL CODE REQUIREMENTS.

PLUMBING NOTES

- 1. ALL PLUMBING EQUIPMENT SHALL BE INSTALLED IN ACCORDANCE WITH CURRENT PLUMBING CODE REQUIREMENTS, ORDINANCES AND INDUSTRY STANDARDS
- 2. PROVIDE ALL EQUIPMENT, ACCESSORIES AND Appliances REQUIRED TO CONSTITUTE A COMPLETE INSTALLATION OF NEW EQUIP.

ELECTRICAL NOTES

1. TEMPORARY WIRING SHALL CONFORM TO N.E.C ARTICLE 305.


KEYED NOTES

- REMOVE AND REINSTALL EXISTING MECHANICAL EQUIPMENT DISCONNECT EXISTING MECH.. & ELEC.., COORDINATE W/ BUILDING MANAGEMENT PRIOR TO SHUT OFF - INSTALL ALL NEW FLASHING, SEE DETAILS A/A201 AND F-A201
- AT OPENING IN ROOF LEFT FROM ABANDONED MECHANICAL EQUIPMENT COVER WITH NEW METAL ROOF DECK MATCHING PROFILE OF EXISTING, OVER LAP EXISTING BY 4" MIN.., SECURE WITH TEK SCREWS AT 4" O.C.
- 3. EXISTING SCUTTLE TO REMAIN
- NEW PVC COATED METAL CURB AT ROOF EDGES.
- EXISTING MECHANICAL UNIT TO BE FLASHED IN PLACE, PROVIDE NEW 2X4 FRAMING OSB SHEATHING AROUND EXISTING BASE, EXTEND MEMBRANE UP SIDES AND FLASH AT TOP, SEE DETAIL P-A202
- SALVAGED SPLASH BLOCKS FOR DOWN SPOUT FROM ROOF ABOVE, REINSTALL AT COMPLETION OF WORK
- EXISTING ANTENNA WIRE CONDUIT, FABRICATE NEW WEATHER HEAD AND SEAL, FLASH BASE, SEE DETAIL K-A201 AND H/A201
- ATTACH EXISTING ANTENNA ARRAY TO NEW STEEL PIPE ANCHORS, VERIFY QUANTITY NEEDED IN FIELD, SEE DETAIL Q2/A202
- ATTACH EXISTING ANTENNA MAST TO NEW STEEL PIPE SUPPORT ANCHORED TO ROOF DECK WITH "CONNECT-IT" ADAPTER SET FOR (2) DIFFERENT SIZED ROUND MEMBERS, COORDINATE WORK WITH BUILDING MANAGEMENT FOR MINIMAL IMPACT ON ANTENNA USE, SEE DETAIL R-A202
- LARGE GUY LINE, PROVIDE NEW GUY LINE ANCHOR TO DECK, SEE DETAIL Q1/A202
- 11. EXISTING ELECTRONIC EQUIPMENT MOUNTED TO STEEL PIPE MAST ON SIDE OF BUILDING, TEMPORARILY REMOVE AND REINSTALL TO INSTALL NEW COPING, COORDINATE WITH BUILDING MANAGEMENT FOR MINIMAL IMPACT ON
- 12. EXISTING GAS LINES TO REMAIN, PROVIDE NEW SUPPORT BLOCKS AT 8'-0" O.C., SEE DETAIL S/A202
- 13. EXISTING EXPANSION JOINT CURB, NEW FLASHING


- 14. EXISTING MECHANICAL UNIT TEMPORARILY REMOVED, BUILD-UP CURB HEIGHT TO A MINIMUM 8" ABOVE ROOF MEMBRANE, PROVIDE NEW CURB FLASHING AND REINSTALL, SEE DETAIL F/A201, RECONNECT ELECTRICAL
- 15. EXISTING FLUE PROVIDE FLASHING FOR A HOT STACK, SEE DETAIL J/A201
- NOT USED
- 17. NEW 30"x36" ROOF HATCH, CUT OPENING IN EXISTING METAL ROOF DECK AND ROOF COVERING TO FIT HATCH, EXTEND EXISTING WALL LADDER TO WITHIN 3" OF TOP OF HATCH, PROVIDE NEW STEEL CHANNEL BRACING EACH SIDE OF OPENING IN METAL DECK AND EXTEND FROM TOP OF WALL TO FIRST STEEL JOIST. PROVIDE NEW MEMBRANE PATCH TO COVER AREA WHERE EXISTING IS REMOVED TO INSTALL CHANNELS, FLASH CURB TO MEMBRANE WITH COMPATIBLE FLASHING MATERIAL, VERIFY EXISTING MEMBRANE MATERIAL IN FIELD. SEE DETAIL W/A204
- 18. SMALL GUY LINE, PROVIDE NEW GUY LINE ANCHOR TO DECK, SEE DETAIL Q2/A202
- 19. EXISTING ANTENNA TOWER SET ON NEW CURB WITH HINGE PLATE
- 20. REMOUNT EXISTING ANTENNA ON NEW FRAMED CURB
- 21. REUSE EXISTING ANTENNA GUY LINES, ADJUST LENGTH TO FIT NEW ANCHORS
- 22. INSTALL NEW DRAIN BOWL ON MODIFIED DRAIN PIPE, SEE DETAIL L/A201.



KEY PLAN



LEGEND




EXISTING ROOF TO REMAIN

NEW WALK PADS OVER NEW ROOF SYSTEM

EXISTING ROOF DRAIN TO RECEIVE NEW RETRO FIT COPPER DRAIN INSERT IN EXISTING BOWL, PROVIDE NEW CAST IRON STRAINER, SEE DETAIL E/A201

EXISTING OVERFLOW DRAIN. UNLESS NOTED OTHERWISE: PROVIDE NEW RETRO FIT COPPER DRAIN INSERT IN EXISTING BOWL, PROVIDE NEW 2" DAMMING RING AND NEW CAST IRON STRAINER, SEE DETAIL E/A210

EXISTING VENT PIPE OR FLUE SHOWN IN APPROXIMATE LOCATION, VERIFY ACTUAL SIZE AND QUANTITY INFIELD, PROVIDE NEW JACK FLASHING, SEE DETAIL G/A201





S

S

S

ROOF PLAN AREA - B

A102

09/12/2008

